

令和 7 年度 黒石市上水道水質検査結果(毎日検査：追子野木地区)

令和7年5月31日 現在

日	4月			5月			6月			7月			8月			9月			10月			11月			12月			1月			2月			3月		
	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素			
1	0.1未満	0.1未満	0.55	0.1未満	0.1未満	0.62																														
2	0.1未満	0.1未満	0.52	0.1未満	0.1未満	0.56																														
3	0.1未満	0.1未満	0.55	0.3未満	0.1未満	0.55																														
4	0.2未満	0.1未満	0.57	0.1未満	0.1未満	0.48																														
5	0.1未満	0.1未満	0.47	0.1未満	0.1未満	0.42																														
6	0.1未満	0.1未満	0.54	0.1未満	0.1未満	0.55																														
7	0.1未満	0.1未満	0.54	0.1未満	0.1未満	0.62																														
8	0.1未満	0.1未満	0.40	0.1未満	0.1未満	0.59																														
9	0.1未満	0.1未満	0.56	0.1未満	0.1未満	0.54																														
10	0.1未満	0.1未満	0.58	0.1未満	0.1未満	0.52																														
11	0.1未満	0.1未満	0.56	0.1未満	0.1未満	0.51																														
12	0.1未満	0.1未満	0.56	0.1未満	0.1未満	0.61																														
13	0.1未満	0.1未満	0.52	0.1未満	0.1未満	0.60																														
14	0.1未満	0.1未満	0.49	0.1未満	0.1未満	0.52																														
15	0.1未満	0.2未満	0.56	0.1未満	0.1未満	0.57																														
16	0.1未満	0.1未満	0.55	0.1未満	0.1未満	0.65																														
17	0.1未満	0.1未満	0.56	0.1未満	0.1未満	0.62																														
18	0.1未満	0.1未満	0.54	0.1未満	0.1未満	0.54																														
19	0.6未満	0.1未満	0.65	0.1未満	0.1未満	0.54																														
20	0.1未満	0.1未満	0.54	0.1未満	0.1未満	0.55																														
21	0.1未満	0.1未満	0.59	0.1未満	0.1未満	0.56																														
22	0.1未満	0.1未満	0.58	0.1未満	0.1未満	0.50																														
23	0.1未満	0.1未満	0.57	0.1未満	0.1未満	0.58																														
24	0.1未満	0.1未満	0.61	0.1未満	0.1未満	0.53																														
25	0.1未満	0.1未満	0.62	0.1未満	0.1未満	0.52																														
26	0.1未満	0.1未満	0.55	0.1未満	0.1未満	0.65																														
27	0.1未満	0.1未満	0.72	0.1未満	0.1未満	0.58																														
28	0.1未満	0.1未満	0.57	0.1未満	0.1未満	0.64																														
29	0.1未満	0.1未満	0.48	0.1未満	0.1未満	0.55																														
30	0.1未満	0.1未満	0.64	0.1未満	0.1未満	0.68																														
31				0.1未満	0.1未満	0.53																														
平均値	0.1未満	0.1未満	0.56	0.1未満	0.1未満	0.56																														
最高値	0.6未満	0.2未満	0.72	0.3未満	0.1未満	0.68																														
最低値	0.1未満	0.1未満	0.40	0.1未満	0.1未満	0.42																														

色度	5度以下	年間平均値	0.1未満	0.1未満	0.56
濁度	2度以下	年間最高値	0.6未満	0.2未満	0.72
残塩	0.1mg/L以上	年間最低値	0.1未満	0.1未満	0.40

令和7年度 黒石市上水道水質検査結果(毎日検査：境松庁舎)

令和7年5月31日 現在

日	4月			5月			6月			7月			8月			9月			10月			11月			12月			1月			2月			3月		
	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素			
1	0.5未満	0.1未満	0.63	0.1未満	0.1未満	0.60																														
2	0.1未満	0.1未満	0.60	0.1未満	0.1未満	0.52																														
3	0.1未満	0.1未満	0.63	0.4未満	0.1未満	0.66																														
4	0.2未満	0.1未満	0.64	0.1未満	0.1未満	0.58																														
5	0.1未満	0.1未満	0.61	0.1未満	0.1未満	0.57																														
6	0.3未満	0.1未満	0.63	0.1未満	0.1未満	0.60																														
7	0.1未満	0.1未満	0.60	0.1未満	0.1未満	0.66																														
8	0.2未満	0.1未満	0.66	0.1未満	0.1未満	0.69																														
9	0.1未満	0.1未満	0.63	0.1未満	0.1未満	0.65																														
10	0.2未満	0.1未満	0.64	0.1未満	0.1未満	0.54																														
11	0.2未満	0.1未満	0.64	0.1未満	0.1未満	0.61																														
12	0.3未満	0.1未満	0.66	0.1未満	0.1未満	0.64																														
13	0.1未満	0.1未満	0.66	0.1未満	0.2未満	0.65																														
14	0.1未満	0.1未満	0.68	0.1未満	0.1未満	0.69																														
15	0.1未満	0.1未満	0.66	0.1未満	0.1未満	0.65																														
16	0.1未満	0.1未満	0.58	0.1未満	0.2未満	0.65																														
17	0.1未満	0.1未満	0.59	0.1未満	0.1未満	0.66																														
18	0.1未満	0.1未満	0.64	0.1未満	0.1未満	0.59																														
19	0.3未満	0.1未満	0.71	0.1未満	0.2未満	0.61																														
20	0.1未満	0.1未満	0.71	0.1未満	0.1未満	0.57																														
21	0.1未満	0.1未満	0.55	0.1未満	0.1未満	0.57																														
22	0.2未満	0.1未満	0.64	0.1未満	0.1未満	0.56																														
23	0.1未満	0.1未満	0.63	0.1未満	0.1未満	0.62																														
24	0.1未満	0.1未満	0.64	0.1未満	0.1未満	0.62																														
25	0.1未満	0.1未満	0.66	0.1未満	0.1未満	0.63																														
26	0.1未満	0.1未満	0.62	0.1未満	0.1未満	0.62																														
27	0.1未満	0.1未満	0.72	0.1未満	0.1未満	0.62																														
28	0.3未満	0.1未満	0.62	0.1未満	0.1未満	0.64																														
29	0.2未満	0.1未満	0.60	0.1未満	0.1未満	0.63																														
30	0.2未満	0.1未満	0.63	0.1未満	0.1未満	0.67																														
31				0.1未満	0.1未満	0.59																														
平均値	0.1未満	0.1未満	0.64	0.1未満	0.1未満	0.62																														
最高値	0.5未満	0.1未満	0.72	0.4未満	0.2未満	0.69																														
最低値	0.1未満	0.1未満	0.55	0.1未満	0.1未満	0.52																														

色度	5度以下	年間平均値	0.1未満	0.1未満	0.63
濁度	2度以下	年間最高値	0.5未満	0.2未満	0.72
残塩	0.1mg/L以上	年間最低値	0.1未満	0.1未満	0.52

令和7年度 黒石市上水道水質検査結果(毎日検査：北地区)

令和7年5月31日 現在

日	4月			5月			6月			7月			8月			9月			10月			11月			12月			1月			2月			3月		
	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素			
1	0.1未満	0.1未満	0.62	0.1未満	0.2未満	0.62																														
2	0.1未満	0.1未満	0.59	0.2未満	0.1未満	0.60																														
3	0.1未満	0.1未満	0.57	0.1未満	0.3未満	0.67																														
4	0.1未満	0.4未満	0.61	0.1未満	0.1未満	0.60																														
5	0.1未満	0.2未満	0.62	0.1未満	0.1未満	0.64																														
6	0.1未満	0.1未満	0.65	0.1未満	0.1未満	0.55																														
7	0.1未満	0.1未満	0.65	0.1未満	0.1未満	0.64																														
8	0.1未満	0.1未満	0.61	0.1未満	0.1未満	0.63																														
9	0.1未満	0.1未満	0.64	0.1未満	0.1未満	0.69																														
10	0.1未満	0.1未満	0.62	0.1未満	0.1未満	0.61																														
11	0.1未満	0.1未満	0.63	0.1未満	0.1未満	0.61																														
12	0.1未満	0.1未満	0.65	0.1未満	0.1未満	0.60																														
13	0.1未満	0.1未満	0.59	0.1未満	0.1未満	0.59																														
14	0.1未満	0.1未満	0.62	0.1未満	0.1未満	0.63																														
15	0.1未満	0.1未満	0.62	0.1未満	0.1未満	0.65																														
16	0.1未満	0.1未満	0.63	0.1未満	0.1未満	0.68																														
17	0.1未満	0.1未満	0.58	0.1未満	0.2未満	0.69																														
18	0.1未満	0.1未満	0.63	0.1未満	0.1未満	0.53																														
19	0.1未満	0.5未満	0.64	0.1未満	0.1未満	0.68																														
20	0.1未満	0.1未満	0.66	0.1未満	0.1未満	0.58																														
21	0.1未満	0.1未満	0.65	0.1未満	0.1未満	0.53																														
22	0.1未満	0.1未満	0.63	0.1未満	0.1未満	0.55																														
23	0.1未満	0.1未満	0.61	0.1未満	0.1未満	0.62																														
24	0.1未満	0.1未満	0.69	0.1未満	0.1未満	0.61																														
25	0.1未満	0.1未満	0.61	0.1未満	0.1未満	0.56																														
26	0.1未満	0.1未満	0.58	0.1未満	0.1未満	0.63																														
27	0.1未満	0.1未満	0.64	0.1未満	0.1未満	0.62																														
28	0.1未満	0.1未満	0.65	0.1未満	0.1未満	0.64																														
29	0.1未満	0.1未満	0.54	0.1未満	0.1未満	0.63																														
30	0.1未満	0.1未満	0.60	0.1未満	0.1未満	0.66																														
31				0.1未満	0.1未満	0.60																														
平均値	0.1未満	0.1未満	0.62	0.1未満	0.1未満	0.62																														
最高値	0.1未満	0.5未満	0.69	0.2未満	0.3未満	0.69																														
最低値	0.1未満	0.1未満	0.54	0.1未満	0.1未満	0.53																														

色度	5度以下	年間平均値	0.1未満	0.1未満	0.62
濁度	2度以下	年間最高値	0.2未満	0.5未満	0.69
残塩	0.1mg/L以上	年間最低値	0.1未満	0.1未満	0.53

令和7年度 黒石市上水道水質検査結果(毎日検査：六郷地区)

令和7年5月31日 現在

日	4月			5月			6月			7月			8月			9月			10月			11月			12月			1月			2月			3月		
	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素			
1	0.1未満	0.1未満	0.60	0.1未満	0.1未満	0.66																														
2	0.1未満	0.3未満	0.60	0.1未満	0.1未満	0.64																														
3	0.1未満	0.1未満	0.60	0.1未満	0.1未満	0.68																														
4	0.1未満	0.1未満	0.63	0.1未満	0.1未満	0.54																														
5	0.1未満	0.1未満	0.57	0.1未満	0.1未満	0.66																														
6	0.1未満	0.1未満	0.66	0.1未満	0.1未満	0.61																														
7	0.1未満	0.1未満	0.60	0.1未満	0.1未満	0.46																														
8	0.1未満	0.4未満	0.61	0.1未満	0.1未満	0.60																														
9	0.1未満	0.1未満	0.62	0.1未満	0.2未満	0.60																														
10	0.1未満	0.4未満	0.60	0.1未満	0.1未満	0.56																														
11	0.1未満	0.1未満	0.60	0.1未満	0.1未満	0.62																														
12	0.1未満	0.1未満	0.60	0.1未満	0.1未満	0.64																														
13	0.1未満	0.1未満	0.59	0.1未満	0.1未満	0.62																														
14	0.1未満	0.1未満	0.61	0.1未満	0.2未満	0.63																														
15	0.1未満	0.1未満	0.58	0.1未満	0.1未満	0.62																														
16	0.1未満	0.1未満	0.56	0.1未満	0.1未満	0.56																														
17	0.1未満	0.1未満	0.59	0.1未満	0.1未満	0.68																														
18	0.1未満	0.1未満	0.61	0.1未満	0.1未満	0.63																														
19	0.1未満	0.1未満	0.74	0.1未満	0.1未満	0.67																														
20	0.1未満	0.1未満	0.76	0.1未満	0.1未満	0.57																														
21	0.1未満	0.1未満	0.64	0.1未満	0.1未満	0.56																														
22	0.1未満	0.1未満	0.62	0.1未満	0.1未満	0.52																														
23	0.1未満	0.1未満	0.62	0.1未満	0.1未満	0.51																														
24	0.1未満	0.1未満	0.71	0.1未満	0.1未満	0.58																														
25	0.1未満	0.2未満	0.64	0.1未満	0.1未満	0.55																														
26	0.1未満	0.1未満	0.59	0.1未満	0.1未満	0.65																														
27	0.1未満	0.1未満	0.70	0.1未満	0.1未満	0.60																														
28	0.1未満	0.3未満	0.64	0.1未満	0.1未満	0.62																														
29	0.1未満	0.2未満	0.45	0.1未満	0.1未満	0.61																														
30	0.1未満	0.1未満	0.62	0.1未満	0.2未満	0.65																														
31				0.1未満	0.1未満	0.62																														
平均値	0.1未満	0.1未満	0.62	0.1未満	0.1未満	0.60																														
最高値	0.1未満	0.4未満	0.76	0.1未満	0.2未満	0.68																														
最低値	0.1未満	0.1未満	0.45	0.1未満	0.1未満	0.46																														

色度	5度以下	年間平均値	0.1未満	0.1未満	0.61
濁度	2度以下	年間最高値	0.1未満	0.4未満	0.76
残塩	0.1mg/L以上	年間最低値	0.1未満	0.1未満	0.45

令和7年度 黒石市上水道水質検査結果(毎日検査：牡丹平地区)

令和7年5月31日 現在

日	4月			5月			6月			7月			8月			9月			10月			11月			12月			1月			2月			3月		
	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素			
1	0.1未満	0.1未満	0.62	0.1未満	0.3未満	0.64																														
2	0.1未満	0.2未満	0.59	0.1未満	0.1未満	0.66																														
3	0.1未満	0.1未満	0.66	0.1未満	0.1未満	0.69																														
4	0.1未満	0.1未満	0.61	0.1未満	0.1未満	0.59																														
5	0.1未満	0.1未満	0.62	0.1未満	0.1未満	0.61																														
6	0.1未満	0.1未満	0.67	0.1未満	0.1未満	0.65																														
7	0.1未満	0.1未満	0.72	0.1未満	0.1未満	0.65																														
8	0.1未満	0.1未満	0.66	0.1未満	0.1未満	0.59																														
9	0.1未満	0.1未満	0.63	0.1未満	0.1未満	0.63																														
10	0.1未満	0.1未満	0.65	0.1未満	0.1未満	0.60																														
11	0.1未満	0.1未満	0.64	0.1未満	0.1未満	0.62																														
12	0.1未満	0.1未満	0.69	0.1未満	0.1未満	0.62																														
13	0.1未満	0.1未満	0.63	0.1未満	0.1未満	0.63																														
14	0.1未満	0.1未満	0.63	0.1未満	0.1未満	0.65																														
15	0.1未満	0.1未満	0.62	0.1未満	0.1未満	0.66																														
16	0.1未満	0.1未満	0.61	0.1未満	0.1未満	0.65																														
17	0.1未満	0.1未満	0.63	0.1未満	0.1未満	0.68																														
18	0.1未満	0.1未満	0.62	0.1未満	0.1未満	0.64																														
19	0.1未満	0.3未満	0.82	0.1未満	0.1未満	0.69																														
20	0.1未満	0.2未満	0.79	0.1未満	0.1未満	0.65																														
21	0.1未満	0.1未満	0.68	0.1未満	0.1未満	0.64																														
22	0.1未満	0.1未満	0.68	0.1未満	0.1未満	0.67																														
23	0.1未満	0.1未満	0.66	0.1未満	0.1未満	0.65																														
24	0.1未満	0.1未満	0.70	0.1未満	0.1未満	0.66																														
25	0.1未満	0.1未満	0.59	0.1未満	0.1未満	0.65																														
26	0.1未満	0.1未満	0.65	0.1未満	0.1未満	0.66																														
27	0.1未満	0.1未満	0.70	0.1未満	0.1未満	0.61																														
28	0.1未満	0.1未満	0.68	0.1未満	0.1未満	0.67																														
29	0.1未満	0.4未満	0.67	0.1未満	0.1未満	0.66																														
30	0.1未満	0.1未満	0.67	0.1未満	0.1未満	0.65																														
31				0.1未満	0.1未満	0.66																														
平均値	0.1未満	0.1未満	0.66	0.1未満	0.1未満	0.64																														
最高値	0.1未満	0.4未満	0.82	0.1未満	0.3未満	0.69																														
最低値	0.1未満	0.1未満	0.59	0.1未満	0.1未満	0.59																														

色度	5度以下	年間平均値	0.1未満	0.1未満	0.65
濁度	2度以下	年間最高値	0.1未満	0.4未満	0.82
残塩	0.1mg/L以上	年間最低値	0.1未満	0.1未満	0.59