

令和7年度 黒石市旧簡易水道水質検査結果(毎日検査：袋地区)

令和7年5月31日 現在

日	4月			5月			6月			7月			8月			9月			10月			11月			12月			1月			2月			3月		
	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素			
1	0.2未満	0.1未満	0.28	0.1未満	0.1未満	0.30																														
2	0.1未満	0.3未満	0.28	0.1未満	0.1未満	0.30																														
3	0.1未満	0.1未満	0.28	0.1未満	0.1未満	0.29																														
4	0.1未満	0.1未満	0.27	0.1未満	0.1未満	0.25																														
5	0.1未満	0.1未満	0.27	0.1未満	0.1未満	0.31																														
6	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.30																														
7	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.31																														
8	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.31																														
9	0.1未満	0.1未満	0.29	0.1未満	0.1未満	0.29																														
10	0.1未満	0.1未満	0.32	0.1未満	0.1未満	0.30																														
11	0.1未満	0.1未満	0.34	0.1未満	0.1未満	0.27																														
12	0.1未満	0.1未満	0.23	0.1未満	0.1未満	0.30																														
13	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.31																														
14	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.31																														
15	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.31																														
16	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.37																														
17	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.34																														
18	0.1未満	0.1未満	0.29	0.1未満	0.1未満	0.36																														
19	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.35																														
20	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.30																														
21	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.30																														
22	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.27																														
23	0.1未満	0.1未満	0.28	0.1未満	0.1未満	0.30																														
24	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.27																														
25	0.5未満	0.1未満	0.26	0.1未満	0.1未満	0.27																														
26	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.32																														
27	0.1未満	0.1未満	0.28	0.1未満	0.1未満	0.26																														
28	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.29																														
29	0.1未満	0.5未満	0.29	0.1未満	0.1未満	0.26																														
30	0.1未満	0.1未満	0.26	0.1未満	0.1未満	0.29																														
31				0.1未満	0.1未満	0.33																														
平均値	0.1未満	0.1未満	0.29	0.1未満	0.1未満	0.30																														
最高値	0.5未満	0.5未満	0.34	0.1未満	0.1未満	0.37																														
最低値	0.1未満	0.1未満	0.23	0.1未満	0.1未満	0.25																														
																											色度	5度以下	年間平均値	0.1未満	0.1未満	0.30				
																											濁度	2度以下	年間最高値	0.5未満	0.5未満	0.37				
																											残塩	0.1mg/L以上	年間最低値	0.1未満	0.1未満	0.23				

令和7年度 黒石市旧簡易水道水質検査結果(毎日検査：落合地区)

令和7年5月31日 現在

日	4月			5月			6月			7月			8月			9月			10月			11月			12月			1月			2月			3月		
	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素			
1	0.2未満	0.1未満	0.30	0.1未満	0.2未満	0.30																														
2	0.1未満	0.4未満	0.26	0.1未満	0.1未満	0.30																														
3	0.1未満	0.1未満	0.27	0.1未満	0.1未満	0.30																														
4	0.1未満	0.1未満	0.25	0.1未満	0.1未満	0.30																														
5	0.1未満	0.1未満	0.29	0.1未満	0.1未満	0.28																														
6	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.31																														
7	0.1未満	0.1未満	0.32	0.1未満	0.1未満	0.33																														
8	0.1未満	0.1未満	0.26	0.1未満	0.1未満	0.31																														
9	0.1未満	0.1未満	0.28	0.1未満	0.1未満	0.30																														
10	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.27																														
11	0.2未満	0.1未満	0.29	0.1未満	0.1未満	0.27																														
12	0.1未満	0.1未満	0.29	0.1未満	0.1未満	0.27																														
13	0.1未満	0.1未満	0.26	0.1未満	0.1未満	0.29																														
14	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.33																														
15	0.1未満	0.1未満	0.28	0.1未満	0.1未満	0.31																														
16	0.1未満	0.1未満	0.26	0.1未満	0.1未満	0.39																														
17	0.1未満	0.1未満	0.29	0.1未満	0.1未満	0.32																														
18	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.34																														
19	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.25																														
20	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.25																														
21	0.1未満	0.1未満	0.26	0.1未満	0.1未満	0.28																														
22	0.1未満	0.1未満	0.27	0.1未満	0.1未満	0.26																														
23	0.1未満	0.1未満	0.27	0.1未満	0.1未満	0.31																														
24	0.1未満	0.1未満	0.34	0.1未満	0.1未満	0.28																														
25	0.5未満	0.1未満	0.32	0.1未満	0.1未満	0.28																														
26	0.1未満	0.1未満	0.26	0.1未満	0.1未満	0.35																														
27	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.25																														
28	0.1未満	0.1未満	0.25	0.1未満	0.1未満	0.27																														
29	0.1未満	0.5未満	0.25	0.1未満	0.1未満	0.27																														
30	0.1未満	0.1未満	0.26	0.1未満	0.1未満	0.34																														
31				0.1未満	0.1未満	0.36																														
平均値	0.1未満	0.1未満	0.28	0.1未満	0.1未満	0.30																														
最高値	0.5未満	0.5未満	0.34	0.1未満	0.2未満	0.39																														
最低値	0.1未満	0.1未満	0.25	0.1未満	0.1未満	0.25																														
																											色度	5度以下	年間平均値	0.1未満	0.1未満	0.29				
																											濁度	2度以下	年間最高値	0.5未満	0.5未満	0.39				
																											残塩	0.1mg/L以上	年間最低値	0.1未満	0.1未満	0.25				

令和7年度 黒石市旧簡易水道水質検査結果(毎日検査：大川原地区)

令和7年5月31日 現在

日	4月			5月			6月			7月			8月			9月			10月			11月			12月			1月			2月			3月		
	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素	色度	濁度	残留塩素			
1	0.1未満	0.1未満	0.27	0.1未満	0.1未満	0.29																														
2	0.1未満	0.1未満	0.26	0.1未満	0.1未満	0.30																														
3	0.1未満	0.1未満	0.29	0.1未満	0.1未満	0.31																														
4	0.1未満	0.1未満	0.28	0.1未満	0.1未満	0.33																														
5	0.1未満	0.1未満	0.32	0.1未満	0.1未満	0.29																														
6	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.29																														
7	0.1未満	0.1未満	0.34	0.1未満	0.1未満	0.32																														
8	0.1未満	0.1未満	0.32	0.1未満	0.1未満	0.33																														
9	0.1未満	0.1未満	0.33	0.1未満	0.1未満	0.31																														
10	0.1未満	0.1未満	0.32	0.1未満	0.1未満	0.31																														
11	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.27																														
12	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.30																														
13	0.1未満	0.1未満	0.32	0.1未満	0.1未満	0.31																														
14	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.31																														
15	0.1未満	0.1未満	0.28	0.1未満	0.1未満	0.31																														
16	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.38																														
17	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.31																														
18	0.1未満	0.1未満	0.34	0.1未満	0.1未満	0.28																														
19	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.31																														
20	0.1未満	0.1未満	0.26	0.1未満	0.1未満	0.32																														
21	0.1未満	0.1未満	0.29	0.1未満	0.1未満	0.26																														
22	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.28																														
23	0.1未満	0.1未満	0.32	0.1未満	0.1未満	0.37																														
24	0.1未満	0.1未満	0.34	0.1未満	0.1未満	0.28																														
25	0.1未満	0.1未満	0.25	0.1未満	0.1未満	0.35																														
26	0.1未満	0.1未満	0.33	0.1未満	0.1未満	0.23																														
27	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.30																														
28	0.1未満	0.1未満	0.32	0.1未満	0.1未満	0.30																														
29	0.1未満	0.3未満	0.25	0.1未満	0.1未満	0.29																														
30	0.1未満	0.1未満	0.31	0.1未満	0.1未満	0.31																														
31				0.1未満	0.1未満	0.37																														
平均値	0.1未満	0.1未満	0.30	0.1未満	0.1未満	0.31																														
最高値	0.1未満	0.3未満	0.34	0.1未満	0.1未満	0.38																														
最低値	0.1未満	0.1未満	0.25	0.1未満	0.1未満	0.23																														
																											色度	5度以下	年間平均値	0.1未満	0.1未満	0.30				
																											濁度	2度以下	年間最高値	0.1未満	0.3未満	0.38				
																											残塩	0.1mg/L以上	年間最低値	0.1未満	0.1未満	0.23				